



**Birbhum District Water Testing Laboratory**  
Office of the Executive Engineer, Birbhum Division P.H. Engineering Dte.  
P.H.E. Complex, S.P. More, Post: Suri, District: Birbhum, Pin: 731101  
Email: birbhumdistrictlab@gmail.com



**TEST REPORT**

Issued to: DAV PUBLIC SCHOOL	Ref Number: DAV/DBRJ/2025-26/580
	Date: 19.03.2026
Source Location: Hetampur, Rajbati, Dubrajpur Birbhum	GRN Number: 192025260520313938
	Date: 18.03.2026
Name of PWSS: NA	Sample Id No: BDWTL/03/2026/08
Type of Source: Stand Post	Sample Collected By: Krishnendu Banerjee (Chemist)
Date of Collection: 23.03.2026	Test Completion Date: 24.03.2026

**CHEMICAL & BACTERIOLOGICAL TEST RESULTS**

Sl. No.	Test Parameters	Unit	Test Methods	Requirement (Acceptable Limit)	Permissible Limit in the absence of alternate Source	Results
				As per IS 10500 : 2012		
1.	pH	---	IS 3025 (Part 11) : 2022 Electrometric method	6.5-8.5	6.5-8.5	7.32
2.	Total Dissolved Solid	mg/L	By TDS Meter	500	2000	169
3.	Turbidity	NTU	IS 3025 (Pt 10) : 2023 Nephelometric Turbidity Meter	1.00	5.00	2.35
4.	Fluoride	mg/L	APHA 24th Edition, 4500FC; 2023 Ion Selective Electrode Method	1.0	1.5	0.210
5.	Total Hardness	mg/L	IS 3025 (Part 21) : 2009 RA 2019 EDTA Titrimetric Method	200	600	100
6.	Iron	mg/L	Spectrophotometric Kit Method	1.0	No Relaxation	0.2
7.	Manganese	mg/L	Spectrophotometric Kit Method	0.1	0.3	0.01
8.	TC	CFU	IS 15185:2016 ISO 9308-1:2014 Membrane Filter Technique Method	Shall not be detectable in any 100 ml of sample		0
9.	FC	CFU	IS 15185:2016 ISO 9308-1:2014 Membrane Filter Technique Method	Shall not be detectable in any 100 ml of sample		0

*[Signature]* 24/3/26

Bacteriologist  
Birbhum Division  
P.H.E Dte.

*[Signature]* 24/03/26

Chemist  
Birbhum Division  
P.H.E Dte.

*[Signature]* 24/03/2026

Junior Engineer  
Birbhum Division  
P.H.E Dte.

*[Signature]* 24/03/2026

Assistant Engineer (RWS)  
Birbhum Sub-Division  
P.H.E Dte.

*[Signature]*  
Headmistress  
DAV PUBLIC SCHOOL  
Hetampur Rajbati, Dubrajpur  
Birbhum, W.B. 731124

*[Signature]*  
Manager  
DAV PUBLIC SCHOOL  
Hetampur Rajbati, Dubrajpur  
Birbhum, W.B. 731124

# Annexure- C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. BDWTL/2026/02

Dated: 24/03/2026

It is certified that an inspection team headed by

Krishnendu Banerjee chemist (Name of Officers with designation)

from Birbhum Division PHED

inspected the DAV PUBLIC SCHOOL, HETAMPUR RAJBATI, DUBRAJPUR

(Name & Address of the school) on 23.03.2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. BDWTL/03/2026/08

dated 24.03.2026 of Birbhum District water Testing Laboratory (PHED Lab)

certified that the

DAV PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 23.03.2027

Banerjee  
Chemist

District W.T. Laboratory  
Birbhum Division, P.H.E. Dte.  
Suri, Birbhum

Signature with Seal

Name

Designation

Name & Address of the Office / Department

Krishnendu Banerjee  
chemist

Office of the  
Executive Engineer,  
Birbhum Division PHEDte.  
S.P. More, Suri, Birbhum

To DAV PUBLIC SCHOOL  
HETAMPUR RAJBATI, DUBRAJPUR  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



[Signature]  
Headmistress  
DAV PUBLIC SCHOOL  
Hetampur Rajbati, Dubrajpur  
Birbhum. W.B. 731124

[Signature]  
Manager  
DAV PUBLIC SCHOOL  
Hetampur Rajbati, Dub  
Birbhum, W.B. 731124