



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Laikhuti Para, Suri, Birbhum, Pin:- 731101

Memo No.: FSR/IND/WB/FES/20182019/45851

Date : 12-08-2026

From :
Divisional Fire Officer
Birbhum Division,
West Bengal Fire & Emergency Services

To :
D A V PUBLIC SCHOOL
Over Plot No- 356, Kh No- 211, JL No- 141, Hetampur Rajbati, PS- Dubrajpur, Dist- Birbhum.

Sub : G+I storied building under group educational occupancy in favour of "D A V Public School", over Plot No- 356, Khatian No-211, J.L.No-141, Hetampur Rajbati, PS-Dubrajpur, Dist-Birbhum (W.B.)

This is in reference to your AIN 211912606300012138 dated 02-Jul-2026 regarding G+I storied building under group educational occupancy in favour of "D A V Public School", over Plot No-356, Khatian No-211, J.L.No-141, Hetampur Rajbati, PS-Dubrajpur, Dist-Birbhum (W.B.).

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Drive way must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To estimate the risk of fire hazards good housekeeping for both inside or outside of the building shall be strictly



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300012138

Headmistress
DAV PUBLIC SCHOOL
Hetampur Rajbati, Dubrajpur
Birbhum W.B. 731124

Manager
DAV PUBLIC SCHOOL
Hetampur Rajbati, Dubrajpur
Birbhum, W.B. 731124

maintained.

4. A Fire control room including a closed-circuit TV system will have to be maintained which observed will floor of the building.
 5. A crew of trained Fire man under the experienced officer shall be maintained round the clock for safety of the fire building.
 6. If required old line shall have to be replacing with new lines, the cables shall always be laid in M.S. conduit pipes continuously bounded to the earth.
 7. Periodical flushing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above-mentioned system.
 8. Fire License shall have to be obtained for strong and processing with LPG and other combustible articles.
 9. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
 10. Transformer and switchgear room shall be protected with automatic CO2 or DCP fire extinguisher conforming specification.
 11. First aid firefighting system shall be provided as per I.S specification.
 12. The notice of firefighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
 13. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event Fire and Testing.
 14. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
 15. Arrangement shall be made for regular checking; testing and proper maintenance of all Fire safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all time.
- The Renewal of Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performances of all the Life and Fire Safety arrangements installation of the building.

Valid Upto : 10-Aug-2029

Memo No.:

FSR/IND/WB/FES/20182019/45851




Headmistress
DAV PUBLIC SCHOOL
Hetampur Rajbati, Dubrajpur
Birbhum W.B. 731124


Manager
DAV PUBLIC SCHOOL
Hetampur Rajbati, Dubrajpur
Birbhum, W.B. 731124

Signature valid

Digitally Signed.
Name: ARINDAM DEBNATH
Date: 12-Aug-2019 20:48:53
Reason: D Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300012138